



REPLACEMENT PUMPS FOR LIFT STATION #21, #22 AND #24

RS-26-014

January 20, 2026

Background

2

- Pumps have a life cycle of 10 – 20 years, are made up of many parts, and are critical to the water/wastewater infrastructure system to move fluids from one location to another.
- In January 2025, staff advertised for a multi-year bid for pump replacements at twelve (12) lift stations and two (2) pump stations.
 - Review of the one (1) response showed that specifications in the bid packet were not quoted as specified.
- On March 18, 2025, City Council approved the rejection of the one (1) response to bid 25-16, Multi-Pump Replacements.
 - Two (2) lift stations and one (1) pump station had pumps replaced in 2025 utilizing cooperative contracts.
 - All other lift and pump stations will be replaced between FY 2026 – FY 2028.

Background Cont.

3

- On October 14, 2025, staff received a quote for replacement and installation of six (6) submersible chopper pumps; two (2) at each of the lift stations below, from Pump Solutions, Inc. in the amount of \$227,857.00, utilizing their contract through The Interlocal Purchasing System (TIPS).
 - Lift Station #21, constructed in 2005, has a rated capacity of 1.0 million gallons per day (MGD).
 - Lift Station #22, constructed in 2010, has a rated capacity of 2.2 MGD.
 - Lift Station #24, constructed in 2005, has a rated capacity of 2.5 MGD.

Pump

4



Recommendation

5

- City Council authorize the City Manager, or designee, to execute a letter of agreement with Pump Solutions, Inc. utilizing purchasing cooperative TIPS contract #23010401, in the amount of \$227,857 and authorize the City Manager, or designee to execute any and all change orders within the amounts set by State and Local law.