



LOA FOR REPLACEMENT OF CLA-VAL  
CONTROL VALVES AT PUMP STATION  
#4

RS-24-147

August 20, 2024

# Background and Findings

- Pump station #4 was built in 1986 and is one of two pump stations that provides potable drinking water for Killeen's Upper Pressure Plane.
- This site pumps an average of 50 MG per month into two (2) 1.5 MG ground storage tanks located on McMillan Mountain, east of Bunny Trail.
- Control valves have a life expectancy of 20 years.
  - Two control valves were installed in 1986.
  - Two control valves were installed in 1995 as part of a site expansion.

# Background Cont.

3

- Prestige Workwide Technologies submitted a quote from BuyBoard Contract #717-23 to provide and install four (4) Cla-Val Control Valves in the amount of \$53,561.76.

# Cla-Val

4



# Recommendation

- City Council authorize the City Manager, or designee, to execute a Letter of Agreement with Prestige Worldwide Technologies in the amount of \$53,561.76 and authorize the City Manager, or designee, to execute any and all change orders within the amounts set by State and Local law.